

**Ministry of the Environment,  
Conservation and Parks**

**Ministère de l'Environnement,  
de la Protection de la nature  
et des Parcs**

Environmental Permissions  
Branch

Direction des permissions  
environnementales

1<sup>st</sup> Floor  
135 St. Clair Avenue W  
Toronto ON M4V 1P5  
**Tel.:** 416 314-8001  
**Fax.:** 416 314-8452

Rez-de-chaussée  
135, avenue St. Clair Ouest  
Toronto ON M4V 1P5  
**Tél. :** 416 314-8001  
**Télééc. :** 416 314-8452

October 16, 2020

Mr. Kenneth Little  
EDP Renewables Canada Ltd.  
219 Dufferin Street, Unit 217C  
Toronto ON M6K 3J1  
By email to: [Ken.Little@edpr.com](mailto:Ken.Little@edpr.com)

**Re: Vibration Monitoring Program  
Nation Rise Wind Farm, Stormont, Ontario  
REA No. 0871-AV3TFM**

Dear Mr. Little:

The Ministry of the Environment, Conservation and Parks has reviewed the following document which was submitted in accordance with Condition K of the Renewable Energy Approval (REA) No. 0871-AV3TFM, issued on May 4, 2018:

- Vibration Monitoring Program, Nation Rise Wind Farm, Stormont, Ontario, dated August 26, 2020 and prepared by Storer J. Boon, Ph.D., P. Eng., Golder Associates Ltd.

The above-noted document details the methods and frequency of collection and management of vibration monitoring data, along with reporting, during the commercial operation phase of the project. Pursuant to Condition K2 of REA No. 0871-AV3TFM, please accept this letter as written approval of the Vibration Monitoring Program.

Nation Rise Wind Farm is requested to ensure that the above-noted document and this letter are made available on the project website.

It should also be noted that while the instrument nests do not fit the strict definition of a well, as they will have their internal void-space grouted, they may still present a pathway for surface water infiltration to the bedrock unit. In order to prevent the creation of pathways allowing water flow from the surface and subsurface, it is recommended that the sealing of the outside of casings be equivalent to that used in water wells and that all work be performed by a licensed well technician.

If you have any questions regarding this letter, please contact Miroslav Ubovic, P.Eng. at 437-216-7610 or [Miroslav.ubovic@ontario.ca](mailto:Miroslav.ubovic@ontario.ca) .

Sincerely,

A handwritten signature in black ink, appearing to read "Bahar Aminvaziri". The signature is fluid and cursive, with a prominent initial "B" and a long, sweeping underline.

Bahar Aminvaziri, P.Eng.  
Director, Section 47.5 Environmental Protection Act  
Environmental Permissions Branch

cc. Tracy Hart, District Manager, Ottawa District Office  
Melissa Lee, Senior Environmental Officer, Cornwell Area Office - Ottawa District  
Nathaniel Roscoe, EDP Renewables Canada Ltd.